



Canadian Standards Association  
Association canadienne de normalisation

# CERTIFICATION RECORD

The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement.

NUMBR 080602U0000 December 9, 1991

CLASS 5851 01 (Label Service)

HOSIWELL ENTERPRISE CO. LTD.  
1F, No 17, Lane 118, Tung Hsing St.  
Nankuang, Taipei, Taiwan

80602

FACTORY

HOSIWELL (THAILAND) CO. LTD.  
Wellgrow Industrial Estate 79, Moo 5  
T. Bangsamuk, A. Bangpakong  
Chachoengsao 24130, Thailand

WIRES - Appliance

TO THE REQUIREMENTS OF CSA STANDARD C22.2 NO 210.2-1988

AWM Class	AWM Group	Temp Deg C	Max Volt	Jacket Type Min Thick (mm)	Overall Covering Type Min Thick (mm)	Min Size Range AWG	Insul. Type Min Thick (mm)	Notes
<b>- SINGLE CONDUCTOR:</b>								
I	A	80	300	-	-	32-10	SR-PVC/.22	1,2
<b>- MULTICONDUCTOR ROUND:</b>								
II	A	105	600	PVC/*	-	32-10	PVC/.76	1,2
II	A	90	300	PVC/*	-	32-10	PVC/.38	1,2
I	A	80	300	PVC/.70	-	32-10	SR-PVC/.22	1,2,3
II	A	75	300	PVC/*	-	32-10	SR-PVC/.22	1,2,3
II	A	75	300	PVC/*	-	32-10	PP/.17	1,2
<b>MULTICONDUCTOR/FLAT:</b>								
II	A	80	300	PVC/.38*	-	32-10	PVC/.38	1,2,3,4
I	A	80	300	-	-	32-10	PVC/.38	1,2,4

Notes: For specific details see Certification report.

1. In all colours except for clear and transparent.
2. Flame test rating FT1.
3. Optional shield.
4. Extruded rip assembly.

\* Per applicable cable diameter.

\*\*\*\*\*