




Canadian Standards Association  
Association canadienne de normalisation

## CERTIFICATION RECORD

The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark -  - to these products according to the terms and conditions of the CSA Service Agreement.

NUMBR 080602V0000 December 9, 1991

CLASS 5831 01 (Label Service)

HOSIWELL ENTERPRISE CO. LTD.  
1F, No 17, Lane 118, Tung-Hsing St.  
Nankuang, Taipei, Taiwan  
FACTORY

80602

HOSIWELL (THAILAND) CO. LTD.  
Wellgrow Industrial Estate 79, Moo 5  
T. Bangsamuk, A. Bangpakong  
Chachoengsao 24130, Thailand

WIRES - Flexible Cord

TO THE REQUIREMENTS OF CSA STD. C22.2 NO 49-M1989.

- Max temperature rating 60C: SPT-1, SPT-2, SPT-3, SVT, SJT.
- Max temperature rating 105C: SPT-1, SPT-2, SPT-3, SVT, SJT.

Notes:

1. Types SVT and SJT may be shielded.
2. The jackets on Types SVT and SJT are rated 60C maximum where exposed to oil.
3. In all colours except clear and transparent.

\*\*\*\*\*